




Extension Board 4 Wiegand



- ▶ Supports 4 Wiegand compatible reader interfaces
- ▶ Supports 4 input points used for Door Contact sensors
- ▶ Supports 4 input points used for Request-to-Exit Devices
- ▶ Supports 8 form-C relay output points
- ▶ Up to a maximum of 4 AEC- 4W-EXT boards can be supported by one Access Easy Controller.
- ▶ IDE Connectors for data bus

The AEC-4W-EXT (4 Wiegand Interface Extension Board) is used in the AEC or AEC Extension. Each board can support four separate Wiegand compatible readers, 4 input points for door contact sensors, 4 input points for "Request-to-Exit" devices/switches, and 8 form-C relay output points to control devices like electric lock to open the door.
(AMERICAS, APR, EMEA)

Functions

Configuration

Each AEC can support up to a maximum of four AEC-4W-EXT boards allowing a maximum configuration of 16 readers per AEC.

Every AEC comes with one AEC-4W-EXT board with options to add another one. Any additional extension board (AEC-4W-EXT board 3 and 4) would be housed in one or more extension enclosures and connected together via the AEC-SER-EXT boards.

Connections

Each reader interface on the board can supply up to 12VDC at 150 mA to power the reader. The reader's LED is also normally controlled through the reader interface.

The optional door contact sensors and request-to-exit inputs for each reader controlled door are supervised with a 6.8 kOhm resistor, placed either in series or in parallel with the device (depending if the contact is normally open or normally closed). The 6.8 kOhm resistors are also supplied with every reader extension package.


The output on the reader extension board is a Form-C relay, dry contact, rated at 24VDC @ 1 Amp. Diodes should be installed across each door strike or magnetic lock. Diodes are also supplied in every reader extension package.

Two IDE data bus connectors are available. One of them is used to interface to the AEC - CPU board. The other is used to extend the data bus to the next AEC-4W-EXT board or AEC-8I8O-EXT board.


Visual Indication

There are several LEDs on the AEC-4W-EXT board that can be used for diagnostic purposes. The LEDs indicate the presence of power, relay states and if the AEC-4W-EXT board is receiving information on the IDE data bus.

Installation/Configuration Notes



Typical HID MiniProx Reader Wiring Diagram



Parts Included

Quant.	Component
1	Reader Expansion Board
1	IDE Interface Cable
1	Board mounting hardware accessories
8	6.8 kOhm resistors
8	Blocking Diodes
1	Installation Guide

Technical Specifications

Dimensions

Enclosure (W x H)	127 x 177 mm (5 x 6.97 inch)
-------------------	---------------------------------

Environmental

Relative Humidity	0% to 90% non-condensing
Temperature (Operating)	0 °C to +50 °C (32 °F to 120 °F)
Temperature (Storage)	0 °C to +55 °C (32 °F to 130 °F)

Inputs

Card Readers	4 Wiegand compatible Readers
Monitoring Points	4 supervised (6.8 kOhm) Door Contact Sensors
Monitoring Points	4 supervised (6.8 kOhm) Request-to-Exit devices

Outputs

Control Points	8 Form-C Relay Output rated at 24 V DC, 1 Amp
----------------	---

Ports

Bus expansion port:	Two 40-pin IDE connectors
---------------------	---------------------------

Power Requirements

Power Supply	+15 V DC
Backup Battery (Optional Backup Battery: Not included in standard package)	12 V DC, 7 Ah rechargeable battery

Ordering Information

Extension Board 4 Wiegand	AEC-4W-EXT
Access Easy Extension - 4 Wiegand Interfaces and Door controls (8 IN/OUT), Fitting parts.	

Europe, Middle East, Africa:
 Bosch Security Systems B.V.
 P.O. Box 80002
 5600 JB Eindhoven, The Netherlands
 Phone: + 31 40 2577 284
 Fax: +31 40 2577 330
 emea.securitysystems@bosch.com
 www.boschsecurity.com

Americas:
 Bosch Security Systems, Inc.
 130 Perinton Parkway
 Fairport, New York, 14450, USA
 Phone: +1 800 289 0096
 Fax: +1 585 223 9180
 security.sales@us.bosch.com
 www.boschsecurity.us

Asia-Pacific:
 Bosch Security Systems Pte Ltd
 38C Jalan Pemimpin
 Singapore 577180
 Phone: +65 6319 3450
 Fax: +65 6319 3499
 apr.securitysystems@bosch.com
 www.boschsecurity.com

Represented by